

(from NSW Health Drinking Water Database)

| Date Collected | Tested Parameter | Test Result | Units | Health Guideline Value | ADW Guideline Value Aesthetic | Sample Comments |
|----------------|------------------|-------------|------------|------------------------|-------------------------------|------------------|
| 28-10-2024 | E. coli | < 1 | mpn/100 mL | 0 | | |
| 28-10-2024 | Free Chlorine | 1.0100 | mg/L | 0.2 - 5 | | |
| 28-10-2024 | pH | 8.0900 | | | 6.5 - 8.5 | |
| 28-10-2024 | Temperature | 16.9000 | C | | 30 | |
| 28-10-2024 | Total Chlorine | 1.3300 | mg/L | 5 | | |
| 28-10-2024 | Total Coliforms | < 1 | mpn/100 mL | 0 | | |
| 28-10-2024 | Turbidity | 0.0000 | NTU | | 5 | |
| 21-10-2024 | E. coli | < 1 | mpn/100 mL | 0 | | |
| 21-10-2024 | Free Chlorine | 1.0200 | mg/L | 0.2 - 5 | | |
| 21-10-2024 | pH | 7.9500 | | | 6.5 - 8.5 | |
| 21-10-2024 | Temperature | 16.2000 | C | | 30 | |
| 21-10-2024 | Total Chlorine | 1.7600 | mg/L | 5 | | |
| 21-10-2024 | Total Coliforms | < 1 | mpn/100 mL | 0 | | |
| 21-10-2024 | Turbidity | 0.0000 | NTU | | 5 | |
| 14-10-2024 | E. coli | < 1 | mpn/100 mL | 0 | | ,Late but tested |
| 14-10-2024 | Free Chlorine | 1.4000 | mg/L | 0.2 - 5 | | ,Late but tested |
| 14-10-2024 | pH | 7.9800 | | | 6.5 - 8.5 | ,Late but tested |
| 14-10-2024 | Temperature | 13.6000 | C | | 30 | ,Late but tested |
| 14-10-2024 | Total Chlorine | 2.2000 | mg/L | 5 | | ,Late but tested |
| 14-10-2024 | Total Coliforms | < 1 | mpn/100 mL | 0 | | ,Late but tested |
| 14-10-2024 | Turbidity | 0.0000 | NTU | | 5 | ,Late but tested |
| 08-10-2024 | E. coli | < 1 | mpn/100 mL | 0 | | |
| 08-10-2024 | Free Chlorine | 0.8570 | mg/L | 0.2 - 5 | | |
| 08-10-2024 | pH | 8.0300 | | | 6.5 - 8.5 | |
| 08-10-2024 | Temperature | 13.9000 | C | | 30 | |
| 08-10-2024 | Total Chlorine | 1.6060 | mg/L | 5 | | |
| 08-10-2024 | Total Coliforms | < 1 | mpn/100 mL | 0 | | |
| 08-10-2024 | Turbidity | 0.0900 | NTU | | 5 | |