

**NSW Drinking Water Database
Organic Chemistry (PFX) Project**

Barcode	Characteristic	Guideline Value	Units	Value	Sample Site Code	Sample Site Location	Lab Name	Date Collected	Date Received	Date Entered
A24OB0100001	PFBS	9999	µg/L	< 0.001	N35	Oberon treatment plant outlet	Enviro lab	11-11-2024	12-11-2024	14-11-2024
A24OB0100001	PFHxS	9999	µg/L	< 0.001	N35	Oberon treatment plant outlet	Enviro lab	11-11-2024	12-11-2024	14-11-2024
A24OB0100001	PFOA	0.56	µg/L	< 0.001	N35	Oberon treatment plant outlet	Enviro lab	11-11-2024	12-11-2024	14-11-2024
A24OB0100001	PFOS	9999	µg/L	< 0.001	N35	Oberon treatment plant outlet	Enviro lab	11-11-2024	12-11-2024	14-11-2024
A24OB0100001	Sum of PFOS and PFHxS	0.07	µg/L	< 0.001	N35	Oberon treatment plant outlet	Enviro lab	11-11-2024	12-11-2024	14-11-2024