

CERTIFICATE OF ANALYSIS

Work Order : WN2300317

Client OBERON COUNCIL

Contact : ANDREW KROL

Address : 137-139 OBERON STREET

OBERON NSW, AUSTRALIA 2787

Telephone

Project : OBERON WASTE WATER

Order number : 17385

C-O-C number

Sampler : ANDREW KROL

Site

Quote number : EN/222

No. of samples received : 4 No. of samples analysed : 4 Page : 1 of 3

Date Samples Received

Laboratory : ALS Water - Newcastle

Contact : Andrea Swan

· 5/585 Maitland Road Newcastle West NSW Australia 2304 Address

: 10-Jan-2023 09:00

Telephone : +61 2 4014 2500

Date Analysis Commenced : 10-Jan-2023

: 19-Jan-2023 12:23 Issue Date



ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

Signatories Position Accreditation Category

Andrea Hropot **Technical Assistant** Microbiology, Newcastle West, NSW Neil Martin Team Leader - Chemistry Chemistry, Newcastle West, NSW

Page : 2 of 3

Work Order : WN2300317

Client : OBERON COUNCIL
Project : OBERON WASTE WATER



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key: CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.

LOR = Limit of reporting

- ^ = This result is computed from individual analyte detections at or above the level of reporting
- ø = ALS is not NATA accredited for these tests.
- ~ = Indicates an estimated value.
- Microbiological Comment: In accordance with ALS work instruction QWI-MIC/04, membrane filtration result is reported an approximate (~) when the count of colonies on the filtered membrane is outside the range of 10 100cfu.
- MW006 is ALS's internal code and is equivalent to AS4276.5.
- CFU = colony forming unit
- MF = membrane filtration

Page : 3 of 3
Work Order : WN2300317

Client : OBERON COUNCIL
Project : OBERON WASTE WATER



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)			Sample ID	Expond Works Discharge EMP1	Up-Stream EMP3	Down-Stream MP4	ExPond Works Discharge EMP1	
	Sampling date / time			09-Jan-2023 09:15	09-Jan-2023 09:00	09-Jan-2023 09:30	09-Jan-2023 10:00	
Compound	CAS Number	LOR	Unit	WN2300317-001	WN2300317-002	WN2300317-003	WN2300317-004	
				Result	Result	Result	Result	
EA005: pH								
pH Value		0.01	pH Unit	7.02	6.76	6.86		
EA025: Total Suspended Solids dried at 104 ± 2°C								
Suspended Solids (SS)		5	mg/L	<5				
EK055A: Ammonia as N								
Ammonia as N	7664-41-7	0.05	mg/L	0.73				
EK059A: Nitrite and Nitrate as N (NOx)								
Nitrite + Nitrate as N		0.05	mg/L	0.56	0.14	0.18		
EK061A: Total Kjeldahl Nitrogen as N								
Total Kjeldahl Nitrogen as N		0.2	mg/L	0.8	0.3	0.2		
EK062A: Total Nitrogen as N								
Total Nitrogen as N		0.1	mg/L	1.3	0.4	0.4		
EK067A: Total Phosphorus as P								
Total Phosphorus as P		0.05	mg/L	0.61	<0.05	0.06		
EP008.WN: Chlorophyll a and Pheophytin	а							
Chlorophyll a		1.0	μg/L	2.0				
Pheophytin a		1.0	μg/L	3.6				
EP021: Total Oil and Grease								
Total Oil and Grease		2	mg/L	<2				
EP030.WN: Biochemical Oxygen Demand	(BOD)							
Biochemical Oxygen Demand		2	mg/L	5				
MW006: Faecal Coliforms & E.coli by MF								
Faecal Coliforms		1	CFU/100mL				1000	