

NSW Drinking Water Database Fluoride Compliance Detailed Report

Barcode	Characteristic	Guideline Value	Units	Value	Water Utility	Supply System	Sample Site Code	Lab Name	Date Collected	Date Received	Date Entered	Sample Comments
325OB0100001	Fluoride	1.5	mg/L	0.98	Oberon Council	Oberon OB01	2	ICPMR-DAL Laboratory	06-01-2025	07-01-2025	10-01-2025	
325OB0100001	Fluoride (WU result)	1.5	mg/L	0.98	Oberon Council	Oberon OB01	2	ICPMR-DAL Laboratory	06-01-2025	07-01-2025	10-01-2025	
325OB0100001	Fluoride Ratio	0.8 - 1.2		1	Oberon Council	Oberon OB01	2	ICPMR-DAL Laboratory	06-01-2025	07-01-2025	10-01-2025	
325OB0100002	Fluoride	1.5	mg/L	1.01	Oberon Council	Oberon OB01	1	ICPMR-DAL Laboratory	03-02-2025	04-02-2025	06-02-2025	
325OB0100002	Fluoride (WU result)	1.5	mg/L	1.07	Oberon Council	Oberon OB01	1	ICPMR-DAL Laboratory	03-02-2025	04-02-2025	06-02-2025	
325OB0100002	Fluoride Ratio	0.8 - 1.2		1.05941	Oberon Council	Oberon OB01	1	ICPMR-DAL Laboratory	03-02-2025	04-02-2025	06-02-2025	
725OB0100002	Fluoride	1.5	mg/L	1	Oberon Council	Oberon OB01	2	ICPMR-DAL Laboratory	06-01-2025	07-01-2025	10-01-2025	
725OB0100002	Fluoride (WU result)	1.5	mg/L	0.98	Oberon Council	Oberon OB01	2	ICPMR-DAL Laboratory	06-01-2025	07-01-2025	10-01-2025	
725OB0100002	Fluoride Ratio	0.8 - 1.2		0.98	Oberon Council	Oberon OB01	2	ICPMR-DAL Laboratory	06-01-2025	07-01-2025	10-01-2025	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	F01		01-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	F01		02-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.02	Oberon Council	Oberon OB01	F01		03-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.03	Oberon Council	Oberon OB01	F01		04-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.02	Oberon Council	Oberon OB01	F01		05-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.09	Oberon Council	Oberon OB01	F01		06-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.16	Oberon Council	Oberon OB01	F01		07-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	F01		08-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	F01		09-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1	Oberon Council	Oberon OB01	F01		10-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	F01		11-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	F01		12-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.08	Oberon Council	Oberon OB01	F01		13-01-2025	N/A	N/A	

Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.03	Oberon Council	Oberon OB01	F01		14-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	F01		15-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.04	Oberon Council	Oberon OB01	F01		16-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.01	Oberon Council	Oberon OB01	F01		17-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1	Oberon Council	Oberon OB01	F01		18-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.01	Oberon Council	Oberon OB01	F01		19-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.01	Oberon Council	Oberon OB01	F01		20-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.98	Oberon Council	Oberon OB01	F01		21-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.96	Oberon Council	Oberon OB01	F01		22-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.07	Oberon Council	Oberon OB01	F01		23-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.03	Oberon Council	Oberon OB01	F01		24-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.03	Oberon Council	Oberon OB01	F01		25-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.96	Oberon Council	Oberon OB01	F01		26-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.911	Oberon Council	Oberon OB01	F01		27-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.856	Oberon Council	Oberon OB01	F01		28-01-2025	N/A	N/A	,low fluoride level in supply tank
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.0517	Oberon Council	Oberon OB01	F01		29-01-2025	N/A	N/A	,operator error, loaded fluoride into mixing tank but forgot to open supply to dosing system
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	F01		30-01-2025	N/A	N/A	
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.16	Oberon Council	Oberon OB01	F01		31-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.04	Oberon Council	Oberon OB01	1		02-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.04	Oberon Council	Oberon OB01	2		02-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	2		09-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	1		09-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.04	Oberon Council	Oberon OB01	1		16-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.04	Oberon Council	Oberon OB01	2		16-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	Oberon Council	Oberon OB01	1		21-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	Oberon Council	Oberon OB01	2		21-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.952	Oberon Council	Oberon OB01	1		28-01-2025	N/A	N/A	
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.964	Oberon Council	Oberon OB01	2		28-01-2025	N/A	N/A	